

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 0.0388 cubic feet per second, but not to exceed 6.0 acre-feet annually, and not to exceed a yearly duty of 5.0 acre-feet per acre of land irrigated from any and/or all sources.

Work must be prosecuted with reasonable diligence and be completed on or before:

November 6, 2001

Proof of completion of work shall be filed before:

December 6, 2001

Water must be placed to beneficial use on or before:

November 6, 2003

Proof of the application of water to beneficial use shall be filed on or before:

December 6, 2003

Map in support of proof of beneficial use shall be filed on or before:


N/A

IN TESTIMONY WHEREOF, I, HUGH RICCI, P.E.,

State Engineer of Nevada, have hereunto set

my hand and the seal of my office,

this 6th day of, November A.D. 2000


State Engineer

Completion of work filed OCT 17 2001

Proof of beneficial use filed _____

Cultural map filed _____ N/A

Certificate No. _____ Issued _____



AMENDED

APPLICATION FOR PERMISSION TO CHANGE POINT OF DIVERSION, MANNER
OF USE AND PLACE OF USE OF THE PUBLIC WATERS OF THE STATE OF
NEVADA HERETOFORE APPROPRIATED

Date of filing in State Engineer's Office DEC 27 1999

Returned to applicant for correction JAN 21 2000

Corrected application filed MAR 06 2000

Map filed MAR 06 2000

The applicant **Ree and Katrina Brinkerhoff**, hereby makes application for permission to change the **Point of Diversion of a portion, the place of use and the manner of use..** of water heretofore appropriated under **State of Nevada Division of Water Resources Permit No. 33055, Certificate No. 13469, Book 47, Page 13469.**

1. The source of water is **Underground.**
2. The amount of water to be changed **.09 c.f.s. but not to exceed 6.0 Acre Feet Annually.**
3. The water to be used for **Irrigation.**
4. The water heretofore permitted for **Irrigation and Domestic Purposes.**
5. The water is to be diverted at the following point **NW¼ NW¼, Section 2, Township 15 South, Range 66 East, Mount Diablo Base and Meridian, Point of Diversion to the Northwest Corner of Section 2 is N 69° 28' 15" W 1,267.49 Feet.**
6. The existing permitted point of diversion is located within **NE¼ NW¼, Section 27, T14S., R66E., M.D.B.&M. or at a point from which N¼ corner of said Section 27 bears N 20° 02' E., a distance of 1,142 feet situated in Clark County, State of Nevada.**
7. Proposed place of use **NW¼ NW¼, of Section 2, Township 15 South, Range 66 East, Mount Diablo Base and Meridian, Parcel 4 of Parcel Map, File 21, Page 11. 1.2 Acres of a 2.50 Acre Parcel.**
8. Existing place of use **8.28 Acres in the NE ¼ NW ¼ , Section 27, T14S., R66E., M.D.B.&M. 1 acre stripped by application No. 62874, 1.2 acre stripped by application No. 65761 Amended.**
9. Use will be from **January 1st to December 31st** of each year.
10. Use was permitted from **January 1st to December 31st** of each year.
11. Description of proposed works **Drilled well, pump and distribution pipes.**
12. Estimated cost of works **\$10,000.00.**
13. Estimated time required to construct works **2 Months.**
14. Estimated time required to complete the application of water to beneficial use **2 Years.**
15. Remarks:

By **Ree H. Brinkerhoff**
s/**Ree H. Brinkerhoff**
P.O. Box 130
Moapa, NV 89025

Compared my/ cmf hf/ cmf

Protested _____

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit to change the point of diversion, place of use, and manner of use of a portion of the waters of an underground source as heretofore granted under Permit 33055, Certificate 13469 is issued subject to the terms and conditions imposed in said Permit 33055, Certificate 13469 and with the understanding that no other rights on the source will be affected by the change proposed herein. The well shall be equipped with a 2-inch opening and a totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of the water begins or before the proof of completion of work is filed. If the well is flowing, a valve must be installed and maintained to prevent waste. This source is located within an area designated by the State Engineer pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The well must be sealed with cement grout, concrete grout or neat cement from ground level to 100 feet.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

(CONTINUED ON PAGE 3)